



Private Fire Hydrant Inspection Field Form
 1616 3rd Avenue North, Nashville, TN 37208
 (615) 862-4600 option 1, then option 5

Name	Address	Phone	Date
HOBBS HOUSE CONDOS COMPLEX# 00735	2116 HOBBS NASHVILLE TN 37215	RD	1/22/2010
W.O.# 777541			Last Inspection Date
Customer ID:	Location ID:	Parcel ID:	
185927	PV105688-001	131-02	6/5/2009

In accordance with Metro Code of Laws, 15.68.030, a copy of this form will be transmitted to Metro Nashville Fire Department. Any discrepancies, remarks, or needed repairs listed in this report indicate the fire hydrant must be re-inspected and/or repaired. All hydrant repairs and restoration work specified shall be completed by the property owner within thirty (30) days after receipt of this notice, and repairs certified to the Fire Marshal.

Initial Inspection _____ 6-Month Inspection _____ Recheck _____
 Inspected By: WGO Contact Name: RICK EATHERLY
 Date / Time Scheduled: Mon. Jan. 25, 2010 @ 10:30 (615)277-0329 (615)384-0973
 Pass _____ Notice to NFD _____ Phone Number: Josh Powell 829-6059(oc)

Hydrant No.	Static PSI	Flow GPM	Residual PSI	Dome Color	Cl ₂	Time On	Time Off	Repairs Needed*	Leaks Y/N	Pass/Fail	Est. Water Usage
1	100	1347	65	GRA	1.4	1010	1015	NO	NO	PASS	6735

HOBBS HOUSE APTS

LOCID 105688 A 33

***Repairs Needed Codes: 1-Paint 2-Oil Parts 3-Tagged 4- Physical Defects 5- Lost**

Comments: _____

Owner's Representative: Jeff Klyore Date: 1-25-10